

# VOC Emission Test Certificate

Thursday 26<sup>th</sup> August 2021

Supplier: SaveBoard (NZ) Limited (17B Manukaka Heights, Hurdon, New Plymouth, 4310, New Zealand)

Sample Description: SaveBOARD Interior Wall & Ceiling Product

Date Tested: August 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>SaveBOARD Interior</b> <b>Wall &amp; Ceiling</b></p>
<p>Total Volatile Organic Compounds Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compounds Rate: 0.004 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate Limit: ≤0.100 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: 0.005 mg/m<sup>2</sup>/hr</p>
<p align="center"><i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by Saveboard and these include LDPE/LLDPE film on both sides – plus a layer of paper on one side.</i></p>	



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant



Dr. Tuan Duong  
Ph.D, B.Eng. (Chemical)  
Senior Consultant

**V2108021**