



CERTIFICATE

Material Fire Test Certificate

IGNL-6067-07-04C I01 R00

DATE OF TEST 15.09.2022
ISSUE DATE 07.02.2023
EXPIRY DATE 06.02.2023

saveBOARD
Paperfaced Internal Lining

SPONSOR
Upcycled Building Materials
Australia Pty Ltd
Level 1, 40 Albert Road
South Melbourne, Victoria 3205

TEST BODY
Ignis Labs Pty Ltd
ABN 36 620 256 617
3 Cooper Place
Queanbeyan NSW 2620
Australia
www.ignislabs.com.au
(02) 6111 2909
Test body is the test location

Introduction

Ignis Labs undertook a test of the saveBOARD Paperfaced Internal Lining. The testing was undertaken in accordance with AS/NZS 3837:1998. The group number was predicted in accordance with AS 5637.1:2015. This is a short form AS 5637.1:2015 report.

BCA requirements specify that the Group Number of a wall or ceiling lining shall be determined in accordance with AS 5637.1:2015. Clause 5.3.1 of AS 5637.1:2015 specifies that only materials for which there are correlations between AS/NZS 3837:1998 results and AS ISO 9705:2003 results shall be tested in accordance with AS/NZS 3837:1998 for the purpose of determining a Group Number. As such, Clause 5.3.3 of AS 5637.1:2005 specifies the suitable materials with permitted correlations, and it includes wood products.

Product Description

The sponsor described the specimen as internal wall and ceiling lining for residential and commercial applications. It is composed of composite packaging consisting of 70% wood fibres, 22% polyethylene, 3% cellulose, 3% aluminium, and 2% other materials. It has a nominal mass of 750 kg/m³ and a nominal thickness of 10 mm. Its end use is as internal wall lining.

The received specimens were a compressed board material with brown paper facing on each side. They had a measured nominal density of approximately 0.95 g/cm³ and a measured nominal thickness of 11.3 mm. The brown paper face of the specimens was tested.

Ignis Labs was not responsible for the sampling stage. All specimens were sampled and fabricated by the test sponsor. The test results apply to the specimens as received.

AS 5637.1 Group Number: 4 | ASEA 266.80 m²/kg

Specimen

The test specimen has characteristics are listed below

Average specimen thickness:	11.31 mm
Average specimen pre-test mass:	109.33 g
Specimen colour:	Brown

Test Method

Six (6) specimens were tested in accordance with the requirements of AS/NZS 3837. Prior to the test, the specimens were conditioned at an ambient temperature of 23 ±2 °C and a relative humidity 50 ±5 %.

Reference Documents

This certificate is based on the following documents:

- Ignis Labs Test Certificate IGNL-6067-07-04C I01R00 dated 29 September 2022.

Notes

- The results of this fire test may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all fire conditions.
- As per Section 9 (n) of AS 5637.1:2015, the determination of the group number was based on the AS/NZS 3837:1998 test.
- Clause A5.2(1)(e) of the BCA allows for evidence of suitability in relation to a report from a professional engineer that certifies that a material, product, form or construction or design fulfils specific requirements of the BCA, sets out the basis on which it is given and the extent to which relevant standards, specifications, rules, codes of practice or other publications have been relied upon to demonstrate it fulfils specific requirements of the BCA.
- This report is provided in accordance with BCA Clause A5.2(1)(e) as a report from a professional engineer. In accordance with BCA Clause A5.2(1)(b) it is demonstrated that the material and testing demonstrates compliance with the requirements of the BCA in accordance with AS 5637.1:2015 in determining the group number.



Benjamin Hughes-Brown | FIEAust CPEng NER APEC Engineer IntPE(Aus)

Chartered Professional Engineer

CPEng, NER (Fire Safety / Mech) 2590091, RPEQ11498, BDC-1875, PRE0000303, DEP0000317, PE0001872
MFireSafety (UWS), BEng (UTS), GradDipBushFire (UWS), DipEngPrac (UTS), DipEng (CIT)

Version: IGNL-QF-031-Issue 03 Revision 01

Disclaimer These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use. The information contained in this document is provided for the sole use of the recipient and no reliance should be placed on the information by any other person. In the event that the information is disclosed or furnished to any other person, Ignis Labs Pty Ltd accepts no liability for any loss or damage incurred by that person whatsoever as a result of using the information.

Copyright © All rights reserved. No part of the content of this document may be reproduced, published, transmitted or adapted in any form or by any means without the written permission of Ignis Labs Pty Ltd.